



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly Owned by Government of Karnataka Undertaking)

Calibration Rating Report

No. EEE/AEE/HTR/

/MT

/BRAZ

373

Enclose

To,

The Assistant Executive Engineer (Ele.)

Attibelli C, O & M Sub Division

BRAZ, BESCOM, Bengaluru.

Sir / Madam,

Sub : Rating / Calibration of HT Installations bearing RR No.:

The HT/EHT Installation having the following details has been rated calibrated on 13/05/25 You are requested to take action on the observation advises recorded below A compliance report shall be sent to this office regarding action taken at your end.

Name & Address of the Consumer	country club.		
RR Number	CDPHT-213	Previously Rated Date	11-02-2025 (NL)
CD in KVA	A0	Nature of Installation	
Connected CT Ratio	2.5/5A	Tariff	HT 2B (U)
Meter Constant	50	SRTPV in Kwp	-
Main Meter Details		Main Meter Seals Found	-
Make	Secura	Main Cover	BRAZ 22439 / 2587/448
SL. No.	90853895	Terminal Cover	BRAZ 05861
Type	E3V054	MD Button	BRAZ 05862
Impulses/KWH	16000	TTB	BRAZ 05863
Caragory	Cat-C/Cat-B	Main Door	BRAZ 05864
Wiring Type	3P3W/3P4W	CT/PT Chamber	UPCI
Year of Manufactured	2023	Halogram Cable	UPCI
Modern Make	Analogics / Nsoft	Modern SL. No.	

Meter Reading

Time & Date	13/5/25 @ 13:50	Anamoly	No Load
RPF / RMD	0.617/0.002	Billing B1 KWH	73.35
Cum kwh	73.56	Billing B2 KWH	72.83
C Lag kvarh	305.44	Billing MD in KVA	0.004
C Lead Kvarh	1.37	Billing Power Factor	0.536
Cum Kvah	318.62	Reset Count	0020
Cum MD KVA	1.753	Phase Sequence	Rev
TOD Cummalative kwh		TOD Billing kwh	
R1/C1		R1/B1	
R2/C2		R2/B2	
R3/C3		R3/B3	
R4/C4		R4/B4	

Meter Parameters

Accucheck Parameters

U1 107.27	PF 0.685	U1	PF
U2	P in Kw 0.00	U2	P in Kw
U3 100.69	Q in kvar 0.00	U3	Q in kvar
A1 0	S in Kva 0.00	A1	S in Kva
A2		A2	S in kva
A3 0		A3	ERROR (%)

Details of Ct's / Pt's :

	Existing	After Replacement	Existing	After Replacement
1. Make	Insion		Kalpa	
2. Type				
3. Class				
4. Insulation level	15/38/95		15/38/95	
5. Burden	2.5		2.5	
6. Ration Connected	2.5/5A		11kva/110/6	
7. Sl. No.				
1. R	2.050	R	10.8760	R
2. Y		Y		Y
3. B	3.051	B	55244/05	B

The installation mtr final reading is given to prepare final bill as per the cited under ref.

Consumer / Representative

Yours Faithfully

demalettel
Assistant Executive Engineer (Elec)
HT Rating Sub Division, Bengaluru