

40178 1278 (12-28)  
FR-2166

-2-  
(For BESCOM Use)

Type of Premises	25,	RR No Painted	yes
Total No of Points/Motors		Slip Inserted in Meter	yes
Total Connected on Phase	7kw -	Book No.	
Load Connected on Phase A		Installation No.	
B		Date of Servicing	
C		Service/Tapping	1000-
Distribution Transformer		Telephone Crossing	
Location	Dollar colony TC	From Pole No.	
Volatge Ratio	11000/440V	Next RR No.	
Capacity	250KVA	Reading Date	16/10/2018
Connected Load	7kw	Service Line	16 sq ft
Meter		Conductor CU/IA	16 sq ft
Type and Make	24555762	Cable WP/IR/CTS	16 sq ft
Capacity	3x5-30A	Pipe	16 sq ft
Initial Reading	2200.0	Earthing	16 sq ft
General		Aerial Fuse	32A
Meter Sealed intact	yes	Cut out	15A
Meter Terminal Cover Seal	yes	Aerial Fuse	15A
Cut Out Sealed	no	Cut out	
Does installation	no	Service Distance	12mtr
Comply with wiring Rules?	yes	Test	-
Are Any Defects Noticed	yes	Phase to earth	0
Rotation of Meter	yes	Neutral to earth	0
Checked OK			
Meter Card Fixed			

**CERTIFIED THAT THE INSTALLATION WAS TESTED AND RATED BY ME**

CONSUMER'S SIGNATURE AYUSH B. B. B. **AYUSH B. B. B.**  
Govt. Licenced Class Electrical Contractor  
Licence No. 160001BNG  
State whether Residence.. Shop Office, Hotel, Restaurant, Cinema Theatre, Hospital, Religious, education, factory(describe), Agricultural, pumping, other Pumping(describe), Cottage Industry(Describe)  
#9, Kodathi, No. 84/3, Carmelram  
BESCOM Muttahallu Sub Division

**For office use only**

Sanction No. \_\_\_\_\_ Ledger Folio \_\_\_\_\_  
Account No. \_\_\_\_\_  
Installation \_\_\_\_\_  
Service No. \_\_\_\_\_

**CHECKED**