

T.P RR NO : DUTP-11677

SL NO : 23643693

Make : LBT 30

(FOR E.S.Co.Ltd. USE)

P.Red : 6985.8 kWh

M.D : 10-18 Mo

RPF : 0.80

blh

* Type of Premises LT-6(A)
Total No. of Points/ Motors 17241
Total connected load 12kW
Load connected on phase A 6)
B 433y
C 2)

R. R. No. Painted 71
Slip inserted in Meter
Book No.
Installation No.
Date of servicing 10/18/2018
Service
Tapping no

Distribution Transformer :

Location Gokul Puh
Voltage ratio 11kv/433v
Capacity 250kva
Connected Load 31

Telephone Crossing no
From pole No. 14
Next R. R. No. DUSC1496
Reading date

Meter :

Type and make LBT
Capacity 30A30
Initial reading 6985

Service Line :

Conductor Cu/IA CU
Cable WP/VIR/CTS VIK
Pipe pvc

General : SL NO : 23643693

Meter sealed intact
Meter terminal cover seal
Cutout sealed
Does Installation comply with wiring Rules? NO
Are any defects noticed? NO
Rotation of meter
Checked O. K.
Meter Card fixed

Earthing :

Aerial Fuse 42 pin
Cutout 15amp
Aerial Fuse 05amp
Cutout 15amp
Service Distance 07m
Test
Phase to Earth
Neutral to Earth

For ELITE ESTATES Certified that the installation was tested and rated by me

Consumers Partner

SRI VENKATESH ELECTRICALS

Contractors/Technician Signature

Class 1 Electrical Engineer & Contractor

#58, 5th Cross, 1st Main Road, Cinema Theatre, Hospital, Religious

Educational, Factory (describe), Agricultural, Pumping, Other pumping (describe) Cottage Industry (describe)

Mob: 8006053222

Engineer

FOR OFFICE USE ONLY

Sanction No.

Ledger Folio
Account No.

W. O. No.

Installation
Service No.

CHECKED

Asst. Engineer

Asst. Executive Engineer

Sr. Asst./Asst. Accounts Officer

