



Bangalore Electricity Supply Company Limited

(wholly owned Government of Karnataka undertaking)

Commissioning & Synchronizing report of SRTPV system (Net / Gross metering)

A	Consumer Details			
1	Name of the Consumer	TINKU DEY		
2	Category	3d , LTI		
3	RR No./Account ID/Connection ID	MAEH3472		
4	Pole Number			
B	Meter Details	Bi-directional Meter		Existing meter
		Main Meter	Check Meter	
1	Meter make: 1ph / 3 ph	HPL Electric & Power Ltd Gurugram India		LT
2	Type	Bi-directional Meter		BuxxxC5
3	Serial number	534785		24553803
4	Capacity	10-60A		5-30A
5	Meter constant	1		1
6	Initial reading (Tri vector parameters)			
	i) Import	4.12KWH	FR= 2438.3KWH	
	ii) Export	4.43 KWH	MD = 3.79KW	
<p>Note:</p> <p>1. The Bi-directional meter records solar generation and existing meter records installation consumption in case of Gross metering.</p> <p>2. The Bi-directional meter records export of solar energy to grid and Import of energy by the installation. Existing meter records the total solar energy generated.</p>				
C	Grid Tied Inverter			
1	Make	DEYE		
2	Serial number	2404096846		

3	Capacity	200 -600VDC (3KW)
4	Input voltage	200-600VDC
5	Output voltage	230/440VA
6	Whether Anti-islanding feature is in working condition	Yes/No
D	PV Module	
1	Make	MUNDRA SOLAR PVT LTD
2	Serial number	LIST ATTACHED
3	Type of module	MONO
4	Capacity of each module	570WP
5	Number of modules	5NO'S
6	Total capacity of module	2.85 KW
E	Earthing verified: DC earthing, AC earthing, LA earthing of SRTPV system	Yes
F	Details of protective system available	<ul style="list-style-type: none"> • AC & DC DB: Yes • Manual Switch solar side: Yes • Relay operated automatic switch at net-meter side: Yes
G	AEE, BESCO inspection & approval letter obtained	Yes
H	Work completion report of SRTPV system obtained from agency	Yes
I	Date of synchronizing with BESCO grid	11/11/2025

AEE(Elc.)/EE(Elc.)
MT S/D/Dvn, -----, BESCO

AEE(Elc.)/EE(Elc.)
O&M-----, BESCO

Name &
Signature of Consumer



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Wholly owned Govt. of Karnataka Undertaking

Summary of SRTPV Application No. 1000698233

This application is registered under National Portal for Solar Rooftop (NAPS)

Application details	
Application No	1000698233
Type of scheme	National Portal for Solar Rooftop (NAPS) Scheme
Application Reference Code (NAPS)	NP-KABE25-8892313
Type of Grid connectivity	Net Metering
Solar Proposed in kWp	2.85
Type of connection	3 Phase LT
Pin code	563130
Latitude	12.872734
Longitude	78.01363
Registered Date	30-Oct-2025 08:21:48 PM

Account details	
Account ID	9004923
Applicant Name	TINKU DEY
Applicant address	S/O TANJAN DEY,
City	S/O TANJAN DEY, ANAMIKA ROY DEY W/O TINKU DEY, PITCHGUNTRAHALLI VILLAGE,
Pincode	W/O
Subdivision code	1243
Subdivision Name	Malur Subdivision
RR Number	MAEH3472
Sanctioned Load	5.0 kW
Connection Type	3-PHASE
Tariff category	LT1

Applicant contact details	
Email Id	dey_tinku@yahoo.co.in
Mobile Number	9949015157

Applicant Tariff details	
Tariff Date	2025-10-30 20:21:48.0
Tariff Rate	2.48

This is a system generated letter and doesn't require signature



BANGALORE ELECTRICTY SUPPLY COMPANY LIMITED

Wholly owned Govt. of Karnataka Undertaking

Ref:

Asst. Executive Engineer (Ele.)(Com.
O&M),BESCOM, Opposite to Court, Bangalore
Road, Malur-563130
Date: 11.11.2025

To,

TINKU DEY
S/O TANJAN DEY,

Madam/Sir,

Sub: Certificate of synchronization of your SRTPV system

Ref: Application Reg No. 1000698233 dated 30.10.2025

Synchronization test of Solar Rooftop PV system of 2.85 kWp, installed on the roof of your installation bearing RR No.: MAEH3472 has been conducted and your SRTPV system successfully synchronized with the BESCOM grid at 400Volts voltage level on 11.11.2025

Yours Faithfully

sd/-

Assistant Executive
Engineer(Ele)
Malur Subdivision
, BESCOM.